

PAROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.....191.....

Dated.....16.03.26.....

It is certified that an inspection team headed by Sri. Niwesh Singh.....(Name of officers with designation) from Asst. Engineer.....(NAME OF Department/ Office) inspected P.H.E.D. Lakhisarai.....

(Name & Address of the school) on 14.03.26..... (date of Inspection), and found that Pokhrama Foundation Academy (Name of School) has safe drinking water for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the School building & the campus as per norms prescribed by the Central/State/U.T. Govt..

The above is valid for a period of One year 16.3.26
15.3.27

Signature with Seal:.....

Name: Sri. Niwesh SinghDesignation: Asst. Engineer

Name & Address of the Office/ Department :

To

Ami Sethi
C.F.D. Pokhrama Foundation Academy
Singhgarh, Lakhisarai
(Name & Address of the Institution)

The filled up certificate should be either in Hindi or English. It is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate a single pdf.

Water Quality Report																						
Name of Division: P.H. Division, LAKHISARAI					District: Lakhisarai																	
Sample collected By: JE					Reporting Date:- 16.03.26																	
Reference No-N/A					Date :- 14.03.26																	
PHYSICO-CHEMICAL & BACTERIOLOGICAL TEST REPORT																						
S.No	Block Name	Name	School Name	Location Details	pH	Turb.	EC umho/cm	TDS Mg/l	TH Mg/l	Ca Mg/l	Mg Mg/l	Cl Mg/l	SO4 Mg/l	Alka Mg/l	NO3 Mg/l	As Mg/l	Fe Mg/l	T Coll MPN 100 ml				
					Desirable Limit* (IS 10500:2012)					6.5-8.5	1.00		500	200	75.00	30.00	250.00	200.00	200.00	45.00	0.010	0.300
					Permissible Limit in absence of alternate source					NR	5.00		2000	600	200.00	100.00	1000.00	400.00	600.00	NR	NR	1
1	SURAGARAH	ANIL SETHI	POKHARMA FOUNDATION ACADEMY	POKHARMA	6.8	3.00	230	120	30	35.50	30.20	40.00	3.00	40.00	2.2	BDL	0.15	-ve				

REMARK- FIT FOR DRINK


 Assistant Engineer Cum (TM)
 P.H. DIVISION, Lakhisarai

Atmishel
16.03.26